
CERTIFICATE

Certified Passive House Component Component-ID 2165sr00 valid until 31st December 2024 Passive House Institute Dr. Wolfgang Feist 64283 Darmstadt Germany



Calegory.	Drain water neat recovery
Manufacturer:	Counter Flow Products B. V.,
	Holten,
	Netherlands
Product name:	Easyfit 1200

This certificate was awarded based on the following criteria:

Tested under standard boundary conditions¹ the system reduces the useful energy demand for shower by

$$40\% \ge 30\%$$

Further properties

Pressure drop tap water at 8 l/min:	0.20 bar
Connection tap water:	Rp 1/2" male
Connection waste water:	DN 50

¹Balanced flow rates, cold water temperature 10 °C, Temperature at shower head 40 °C, waste water temperature 35 °C, negligible pipe length, shower time 6 min, flow rate 8 l/min

 Passive House
 phE
 phD
 phC
 phA
 phA+







www.passivehouse.com