


CERTIFICATE

Certified Passive House Component

Component-ID 2166sr00 valid until 31st December 2024

Passive House Institute
Dr. Wolfgang Feist
64283 Darmstadt
Germany



Category: **Drain water heat recovery**
Manufacturer: **Counter Flow Products B. V.,
Holten,
Netherlands**
Product name: **showerpipe VX 1700**

This certificate was awarded based on the following criteria:

Tested under standard boundary conditions¹ the system reduces the useful energy demand for shower by

$$52\% \geq 30\%$$

Further properties

Pressure drop tap water at 8 l/min: 0.21 bar
Connection tap water: Rp 1/2" female
Connection waste water: DN 50

nominal efficiency
63 %
effective dead time
5 s
design flow rate
8 l/min



¹Balanced flow rates, cold water temperature 10 °C,
Temperature at shower head 40 °C, waste water temperature 35 °C,
negligible pipe length, shower time 6 min,
flow rate 8 l/min

Passive House
efficiency class

phE

phD

phC

phB

phA

phA+

all climate zones



**CERTIFIED
COMPONENT**

Passive House Institute